



FACULTEIT INGENIEURSWETENSCHAPPEN EN
ARCHITECTUUR
Vakgroep TEXTIELKUNDE
Technologiepark 907, B-9052 Gent (Zwijnaarde)
T +32 9 264 57 35 - F +32 9 264 58 46
http://textiles.UGent.be
textiles@UGent.be

TEST REPORT 16-0224-02

Translation of test report 16-0224-01 dated 21 March 2016

Samples received :

Name	Date of receipt
Quality Faro/Olympia	26/02/2016

Aim of the test:

Determination of the slip resistance

Test conditions:

Slip resistance

Standard: NF EN 14231

Method: A sliding block covered with the standard rubber is fitted on a pendulum.

After releasing the pendulum from its horizontal position, the loss of energy due to the sliding over the test surface is measured by registering the reduction of the

pendulum on a scale from 0 to 150.

SRV=0: no friction

SRV=150: highest friction

Number of tests: 5 dry tests and 5 dry tests in the opposite direction + 5 wet and 5 wet tests in the

opposite direction

The tests were performed in week 11/2016.

OBTAINED RESULTS

Slip resistance

repetition	Dry	Dry in the opposite direction
	SRV	SRV
1	72	72
2	69	72
3	69	75
4	72	72
5	71	75
average	70.6	73.2
Average dry	71.9	

repetition	Wet	Wet in the opposite direction	
	SRV	SRV	
1	57	69	
2	57	69	
3	54	66	
4	57	66	
5	57	66	
average	56.4	67.2	
Average wet		61.8	

Johanna Louwagie Head of Physical Tests Prof. Dr. Paul KIEKENS, dr. h. c. Head of Department